



STANDARD MATERIAL NOTES:

- #10 GA. STL. WIRE, CRIPPED & INTERWOVEN TO FORM 1 1/2" DIAMOND MESH
- 1 1/4"x3/8"x1/8" CHANNEL, MORTISED & TENONED
- 1 1/2"x1/8" CHANNEL, MORTISED & TENONED
- CENTER REINFORCEMENT CROSSBARS - CONSIST OF 1 1/2"x1/8" CHANNELS RIVETED TOGETHER
- TOP HORIZ. CAPPING BARS 1/4"x2" FLAT SECURED TO TOP FRAMING CHANNELS 1/4" x 1/4" BOLTS & WASHERS
- BOTTOM FRAMING CHANNELS 1/4" x 1/4" BOLTS & WASHERS
- RIVETS ARE 1/4" DIA. x 1/2" LONG
- LATE POSTS BASE ON PROJECT REQUIREMENTS
- 1/4"x3/8" VERT. FLATS BOLTED BETWEEN CHANNEL FRAMING
- 2 1/8"x3/8" ANGLE STANCHIONS WELDED TO 12"x12"x5/16" FLOOR PLATE
- 2"x3"x1/8" STANCHION WELDED TO 12"x12"x5/16" FLOOR PLATE
- FLOOR SHOES SIZED TO SUIT VERTICAL FRAMING AND TO PROVIDE APPROX 3 1/2" CLEARANCE FROM FLOOR TO FLOOR

ACME 8021 1/2" x 1/8" Wire Mesh	
EXHIBIT NUMBER	8021 1/2" x 1/8" Wire Mesh
CUSTOMER	NAME
LOCATION	LOCATION
TITLE STANDARD DUTY WOVEN WIRE DETAILS	
JOB NO. XXX	DATE NO. D-XX